

Annexure - C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.01

Date:08.03.2026


It is a certified an inspection team headed by MEDICAL OFFICER PRIMARY HEALTH CENTER, TARANAGAR, TA. SANDUR, DIST. BALLARI inspected the BKG GLOBAL SCHOOL, BALLARI ROAD, KRISHNA NAGAR, SANDUR, BALLARI DISTRICT, KARNATAKA-583119 on 03.03.2026 and on the basis of water Test report (attached) bearing no. 242-245-2025/26 Dated 17.09.2025 of DISTRICT WATER TESTING LABORATORY HISAR certified that the BKG GLOBAL SCHOOL has safe drinking water facilities for the students and member of staff of the institution school is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T Govt.

The certificate is valid till three years.

Signature with Seal: 
ಕಿರಿಯ ಅಶೋಕ ನಿರೀಕ್ಷಕರು
ಪುಸ್ತಕ, ಸರಡೂರು
Name: K. Shiravari
Designation: Junior health inspector
Name & Address of the Office: TMC, Sandur
Department:

To,

BKG GLOBAL SCHOOL,
BALLARI ROAD, KRISHNA NAGAR,
SANDUR, BALLARI DISTRICT,
KARNATAKA-583119


Principal
BKG Global School
Krishna Nagar, Sandur

For BKG Global School


Managing Trustee

Date:- 17/09/2025

Subject: Physical/ Chemical Examination Report of Water Sample.

Sample ID: 242/243/244/245 Classification: Private Sender: BKG GLOBAL SCHOOL Location:- RO WATER SAMPLE AT BKG GLOBAL SCHOOL	Sample Details	Date & Time
	Collected By	12/09/2025 3:00PM
	Collection Date	12/09/2025 3:00PM
	Received at lab	12/09/2025 3:00PM
	Tested at Lab	15/09/2025

Test Result


SL NO	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)
1	Total Dissolved Solids	30.01	500 mg/lit	2000 mg/lit
2	Total Hardness as CaCo3	10	200 mg/lit	600 mg/lit
3	Calcium as Ca	3.2	75 mg/lit	200 mg/lit
4	Magnesium as Mg	0.72	30 mg/lit	100 mg/lit
5	Iron as Fe	0.01	1.0 mg/lit	1.0 mg/lit
6	Chloride as Cl	7	250 mg/lit	1000 mg/lit
7	Sulphate as So4	4.1	200 mg/lit	400 mg/lit
8	Flouride as F	0.15	1.0 mg/lit	1.5 mg/lit
9	Nitrate as No3	0.1	45 mg/lit	45 mg/lit
10	pH	6.52	6.5-8.5	6.5 - 8.5
11	Alkalinity	10	200 mg/lit	600 mg/lit

Remarks: - The Results given above are related to the sample as received and tested in HISAR Lab.

- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters, the water sample is found "Potable"


Principal
BKG Global School
Krishna Nagar, Sandur


DISTRICT WATER TESTING LABORATORY HISAR
ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ, ತಾರಾನಗರ
ಸಂಪೂರ್ಣ ತಾ. ಬಳಾರಿ ದ.

For BKG Global School


Managing Trustee